

Cable & Wireless Communications

Datacentre Specifications

	DC1	DC2	DC3	DC4	DC5	DC6 (Jul09)	DC7 (Aug09)	DC8 (Jun10)	DC9 (Jun10)
MONITORING & REPORTING									
Bandwidth utilisation graphs - a secure portal is supplied as standard (NMIS).	Y	Y	Y	Y	Y	Y	Y	Y	Y
Power utilisation readings checked regularly and available by request. Customer is responsible for managing power draw.	Y	Y	Y	Y	Y	Y	Y	Y	Y
EXTRA SERVICES AVAILABLE									
DDoS mitigation.	recommended	recommended	recommended	recommended	recommended	recommended	recommended	recommended	recommended
Remote or 'eyes and hands' support such as hard and soft reboots, console access etc.	Y	Y	Y	Y	Y	Y	Y	Y	Y
Managed Services (POA) Rack/ stack, cabling, maintenance contracts.	Y	Y	Y	Y	Y	Y	Y	Y	Y
Full range of network connectivity, local and international including: Dual IP connections as standard, Usage portal, Direct Internet Access and Private Line Circuits, fully redundant off-island bandwidth to UK and rest of world.	Y	Y	Y	Y	Y	Y	Y	Y	Y
Ethernet/GigE Copper, RJ45 presentation handoff. Dual GigE provided as standard. Other options available on request. Diversely routed from separate access nodes. HSRP protection provided as standard, BGP peering on request (additional installation fee applies but no additional rental charge for BGP).	Y	Y	Y	Y	Y	Y	Y	Y	Y
Fibre cross-connects to interconnect cabinets in different locations. Single mode and multi mode with LC presentation is standard. Subject to availability and survey.	Y	Y	Y	Y	Y	Y	Y	Y	Y
Tape backup and restore. Customer to provide tapes.	Y	Y	Y	Y	Y	Y	Y	Y	Y
AMENITIES INCLUDED:									
Separate preparation area away from data floor - by negotiation.	Y	Y	Y	Y	Y	Y	Y	Y	Y
Storage area for manuals, spares, small tools etc.	by negotiation	by negotiation	by negotiation	by negotiation	by negotiation	by negotiation	by negotiation	by negotiation	by negotiation
WCs.	Y	Y	Y	Y	Y	Y	Y	Y	Y
Access to lunch room.	Y	Y	Y	Y	Y	Y	Y	Y	Y
Snack and drink vending machines.	Y	Y	Y	Y	Y	Y	Y	Y	Y
CUSTOMER PROVIDED EQUIPMENT									
Standard Rack Size. Customers may supply own racks if preferred, although standard dimensions apply. Other options can be discussed.	600 x 900 (42u)	606 x 1009 (42u)	606 x 1009 (42u)	606 x 1009 (42u)	606 x 1009 (42u)	606 x 1009 (42u)	606 x 1009 (42u)	606 x 1009 (42u)	606 x 1009 (42u)
Customers must supply own rack power strips even if taking CW racks.	Y	Y	Y	Y	Y	Y	Y	Y	Y
Tapes and kit for tape backup if required.	Y	Y	Y	Y	Y	Y	Y	Y	Y

December 2010